

# Disconnect terminal block - UT 4-HEDI - 3046249

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://download.phoenixcontact.com>)



Disconnect terminal block, Connection type: Screw connection, Cross section: 0.14 mm<sup>2</sup> - 6 mm<sup>2</sup>, AWG: 26 - 10, Nominal current: 20 A, Nominal voltage: 500 V, Length: 57.8 mm, Width: 6.2 mm, Color: Black/orange, Assembly: NS 35/7,5, NS 35/15

## Product Features

- An extremely compact design
- Tested for railway applications
- Test connection on both sides in safety lever

## Key commercial data

<b>package_quantity</b>	50
<b>GTIN</b>	4017918960940

## Technical data

### General

<b>Number of levels</b>	1
<b>Number of connections</b>	2
<b>Color</b>	Black/orange
<b>Insulating material</b>	PA
<b>Inflammability class according to UL 94</b>	V0
<b>Area of application</b>	Railway industry
<b>Area of application</b>	Mechanical engineering
<b>Area of application</b>	Plant engineering

### General

<b>Maximum load current</b>	16 A (with 6 mm <sup>2</sup> conductor cross section)
<b>Rated surge voltage</b>	6 kV
<b>Pollution degree</b>	3
<b>Surge voltage category</b>	III
<b>Insulating material group</b>	I
<b>Connection in acc. with standard</b>	IEC 60947-7-1
<b>Nominal current I<sub>N</sub></b>	20 A
<b>Nominal voltage U<sub>N</sub></b>	500 V
<b>Open side panel</b>	nein
<b>Shock protection test specification</b>	DIN EN 50274 (VDE 0660-514):2002-11
<b>Back of the hand protection</b>	guaranteed

# Disconnect terminal block - UT 4-HEDI - 3046249

## Technical data

### General

Finger protection	guaranteed
Surge voltage test setpoint	7.3 kV
Result of surge voltage test	Test passed
Power frequency withstand voltage setpoint	1.89 kV
Result of power-frequency withstand voltage test	Test passed
Checking the mechanical stability of terminal points (5 x conductor connection)	Test passed
Bending test rotation speed	10 rpm
Bending test turns	135
Bending test conductor cross section/weight	0.14 mm <sup>2</sup> / 0.2 kg
Bending test conductor cross section/weight	4 mm <sup>2</sup> / 0.9 kg
Bending test conductor cross section/weight	6 mm <sup>2</sup> / 1.4 kg
Result of bending test	Test passed
Conductor cross section tensile test	0.14 mm <sup>2</sup>
Tractive force setpoint	10 N
Conductor cross section tensile test	4 mm <sup>2</sup>
Tractive force setpoint	60 N
Conductor cross section tensile test	6 mm <sup>2</sup>
Tractive force setpoint	80 N
Tensile test result	Test passed
Tight fit on carrier	NS 35
Setpoint	1 N
Result of tight fit test	Test passed
Result of voltage drop test	Test passed
Temperature-rise test	Test passed
Conductor cross section short circuit testing	4 mm <sup>2</sup>
Short-time current	0.48 kA
Short circuit stability result	Test passed
Proof of thermal characteristics (needle flame) effective duration	30 s
Result of thermal test	Test passed
Test specification, oscillation, broadband noise	DIN EN 50155 (VDE 0115-200):2008-03
Test spectrum	Service life test category 1, class B, body mounted
Test frequency	f <sub>1</sub> = 5 Hz to f <sub>2</sub> = 150 Hz
ASD level	0.02 g <sup>2</sup> /Hz
Acceleration	0.8 g
Test duration per axis	5 h
Test directions	X-, Y- and Z-axis
Oscillation, broadband noise test result	Test passed
Test specification, shock test	DIN EN 50155 (VDE 0115-200):2008-03
Shock form	Half-sine
Acceleration	5 g

# Disconnect terminal block - UT 4-HEDI - 3046249

## Technical data

### General

Shock duration	30 ms
Number of shocks per direction	3
Test directions	X-, Y- and Z-axis (pos. and neg.)
Shock test result	Test passed
Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21))	120 °C

### Dimensions

Width	6.2 mm
Length	57.8 mm
Height NS 35/7,5	73 mm
Height NS 35/15	80.5 mm

### Connection data

Connection in acc. with standard	IEC 60947-7-1
Connection method	Screw connection
Conductor cross section solid min.	0.14 mm <sup>2</sup>
Conductor cross section solid max.	6 mm <sup>2</sup>
Conductor cross section AWG/kcmil min.	26
Conductor cross section AWG/kcmil max	10
Conductor cross section stranded min.	0.14 mm <sup>2</sup>
Conductor cross section stranded max.	6 mm <sup>2</sup>
Min. AWG conductor cross section, stranded	26
Max. AWG conductor cross section, stranded	10
Conductor cross section stranded, with ferrule without plastic sleeve min.	0.14 mm <sup>2</sup>
Conductor cross section stranded, with ferrule without plastic sleeve max.	4 mm <sup>2</sup>
Conductor cross section stranded, with ferrule with plastic sleeve min.	0.14 mm <sup>2</sup>
Conductor cross section stranded, with ferrule with plastic sleeve max.	4 mm <sup>2</sup>
2 conductors with same cross section, solid min.	0.14 mm <sup>2</sup>
2 conductors with same cross section, solid max.	1.5 mm <sup>2</sup>
2 conductors with same cross section, stranded min.	0.14 mm <sup>2</sup>
2 conductors with same cross section, stranded max.	1.5 mm <sup>2</sup>
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, min.	0.5 mm <sup>2</sup>
2 conductors with same cross section, stranded, TWIN ferrules with plastic sleeve, max.	2.5 mm <sup>2</sup>
2 conductors with same cross section, stranded, ferrules without plastic sleeve, min.	0.14 mm <sup>2</sup>
2 conductors with same cross section, stranded, ferrules without plastic sleeve, max.	1.5 mm <sup>2</sup>
Stripping length	9 mm

# Disconnect terminal block - UT 4-HEDI - 3046249

## Technical data

### Connection data

Internal cylindrical gage	A4
Screw thread	M3
Tightening torque, min	0.6 Nm
Tightening torque max	0.8 Nm

## classifications

### eCl@ss

eCl@ss 4.0	27141117
eCl@ss 4.1	27141117
eCl@ss 5.0	27141120
eCl@ss 5.1	27141120
eCl@ss 6.0	27141120
eCl@ss 7.0	27141120
eCl@ss 8.0	27141126

### ETIM

ETIM 2.0	EC000902
ETIM 3.0	EC000902
ETIM 4.0	EC000902
ETIM 5.0	EC000902


### UNSPSC

UNSPSC 6.01	30211811
UNSPSC 7.0901	39121410
UNSPSC 11	39121410
UNSPSC 12.01	39121410
UNSPSC 13.2	39121410

## approvals

CSA / UL Recognized / cUL Recognized / LR / GL / RS / GOST / DNV / cULus Recognized /

### Approval details

		
<b>Usegroups</b>	<b>B</b>	<b>C</b>
Nominal voltage UN	600 V	600 V
Nominal current IN	16 A	16 A
mm <sup>2</sup> /AWG/kcmil	26-10	26-10

# Disconnect terminal block - UT 4-HEDI - 3046249

## approvals

**UL Recognized**

Usegroups	B	C
Nominal voltage UN	600 V	600 V
Nominal current IN	16 A	16 A
mm <sup>2</sup> /AWG/kcmil	26-10	26-10

**cUL Recognized**

Usegroups	B	C
Nominal voltage UN	600 V	600 V
Nominal current IN	16 A	16 A
mm <sup>2</sup> /AWG/kcmil	26-10	26-10

LR

GL

RS

GOST

DNV

**cULus Recognized**

## accessories

### Screwdriver tools

SZS 0,6X3,5 - 1205053



## Disconnect terminal block - UT 4-HEDI - 3046249

accessories

### Marker pen

B-STIFT - 1051993



X-PEN 0,35 - 0811228



### Bridge

VS - 3004207



FBS 2-6 - 3030336



FBS 3-6 - 3030242



# Disconnect terminal block - UT 4-HEDI - 3046249

## accessories

FBS 4-6 - 3030255



FBS 5-6 - 3030349



FBS 10-6 - 3030271



FBS 20-6 - 3030365



FBSR 2-6 - 3033715



FBSR 3-6 - 3001594



## Disconnect terminal block - UT 4-HEDI - 3046249

accessories

---

FBSR 4-6 - 3001595



FBSR 5-6 - 3001596



FBSR 10-6 - 3033716



### Mounting rail

NS 35/ 7,5 PERF 2000MM - 0801733



NS 35/ 7,5 UNPERF 2000MM - 0801681





## Disconnect terminal block - UT 4-HEDI - 3046249

### accessories

NS 35/ 7,5 WH PERF 2000MM - 1204119



---

NS 35/ 7,5 WH UNPERF 2000MM - 1204122



---

NS 35/ 7,5 AL UNPERF 2000MM - 0801704



---

NS 35/ 7,5 ZN PERF 2000MM - 1206421



---

NS 35/ 7,5 ZN UNPERF 2000MM - 1206434



---

NS 35/ 7,5 CU UNPERF 2000MM - 0801762



## Disconnect terminal block - UT 4-HEDI - 3046249

accessories

---

NS 35/ 7,5 CAP - 1206560



NS 35/15 PERF 2000MM - 1201730



NS 35/15 UNPERF 2000MM - 1201714



NS 35/15 WH PERF 2000MM - 0806602



NS 35/15 WH UNPERF 2000MM - 1204135



## Disconnect terminal block - UT 4-HEDI - 3046249

### accessories

NS 35/15 AL UNPERF 2000MM - 1201756



---

NS 35/15 ZN PERF 2000MM - 1206599



---

NS 35/15 ZN UNPERF 2000MM - 1206586



---

NS 35/15 CU UNPERF 2000MM - 1201895



---

NS 35/15 CAP - 1206573



---

NS 35/15-2,3 UNPERF 2000MM - 1201798



# Disconnect terminal block - UT 4-HEDI - 3046249

accessories

---

## Terminal marking

ZB 5 :UNBEDRUCKT - 1050004



UC-TM 5 - 0818108



UCT-TM 5 - 0828734



ZB 6:UNBEDRUCKT - 1051003



UC-TM 6 - 0818085



## Disconnect terminal block - UT 4-HEDI - 3046249

accessories

UCT-TM 6 - 0828736



---

### Labeled terminal marker

ZB 5 CUS - 0824962



---

ZB 5,LGS:FORTL.ZAHLEN - 1050017



---

ZB 5,QR:FORTL.ZAHLEN - 1050020



---

ZB 5,LGS:GLEICHE ZAHLEN - 1050033



## Disconnect terminal block - UT 4-HEDI - 3046249

### accessories

ZB 5,LGS:L1-N,PE - 1050415



---

UC-TM 5 CUS - 0824581



---

UCT-TM 5 CUS - 0829595



---

ZB 6 CUS - 0824992



---

ZB 6,LGS:FORTL.ZAHLEN - 1051016



---

ZB 6,QR:FORTL.ZAHLEN - 1051029



## Disconnect terminal block - UT 4-HEDI - 3046249

accessories

---

ZB 6,LGS:GLEICHE ZAHLEN - 1051032



ZB 6,LGS:L1-N,PE - 1051414



ZB 6,LGS:U-N - 1051430



UC-TM 6 CUS - 0824589



UCT-TM 6 CUS - 0829602



**End block**

# Disconnect terminal block - UT 4-HEDI - 3046249

accessories

CLIPFIX 35 - 3022218



CLIPFIX 35-5 - 3022276



E/NS 35 N - 0800886



## Drawings

Circuit diagram

