GV7AS107

voltage release TeSys GV7-AS - 110...130 V AC 50/60Hz



Main

Commercialised
GV7R
GV7AS
Shunt trip
Set of 10

Complementary

110130 V AC 50/60 Hz	
0.71.1 Un	
600 V AC conforming to CSA C22.2 No 14 control circuit 690 V AC conforming to IEC 60947-1 control circuit 600 V AC conforming to UL 508 control circuit	
0.20.75 Ue	
< 10 VA for AC network	
< 5 VA for AC network	
< 50 ms conforming to IEC 60947-1	
100 %	
Control circuit: screw clamp terminals 1 cable 1.5 mm² - cable stiffness: solid Control circuit: screw clamp terminals 1 cable 1.5 mm² - cable stiffness: flexible - without cable end Control circuit: screw clamp terminals 1 cable 1 mm² - cable stiffness: flexible - with cable end	
Control circuit: 1.2 N.m - on screw clamp terminals	
0.11 kg	

Contractual warranty

Outractual warranty		
Period	18 months	