

SAK Series, Accessories
QB 4 WI RA6 IS**Weidmüller Interface GmbH & Co. KG**
Klingenbergstraße 16
D-32758 Detmold
Germany
Fon: +49 5231 14-0
Fax: +49 5231 14-292083
www.weidmueller.com

Cross-connection element, insulated
6.0, 6.5 mm and 8.0 mm pitches

General ordering data

| | |
|------------|--|
| Type | QB 4 WI RA6 IS |
| Order No. | 0482900000 |
| Version | SAK Series, Accessories, Cross-connector, for cross-connection link, No. of poles: 4 |
| GTIN (EAN) | 4008190086169 |
| Qty. | 50 pc(s). |

Datenblatt

**SAK Series, Accessories
QB 4 WI RA6 IS**

Weidmüller Interface GmbH & Co. KG
 Klingenbergstraße 16
 D-32758 Detmold
 Germany
 Fon: +49 5231 14-0
 Fax: +49 5231 14-292083
 www.weidmueller.com

Technische Daten

Dimensions and weights

| | | | |
|--------|-------|------------|--------|
| Length | 28 mm | Width | 3 mm |
| Height | 19 mm | Net weight | 1.65 g |

Temperatures

| | | | |
|----------------------------------|--------|----------------------------------|--------|
| Operating temperature | | Storage temperature | |
| Continuous operating temp., min. | -50 °C | Continuous operating temp., max. | 100 °C |

Additional technical data

| | | | |
|--------------------------|---------------------------|---------------------|-----------------|
| Explosion-tested version | No | Installation advice | Direct mounting |
| Version | for cross-connection link | | |

Material data

| | | | |
|---------------------------|-------|--------|------|
| Material | PA 66 | Colour | Grey |
| UL 94 flammability rating | V-2 | | |

System specifications

| | |
|----------------|-------------------------|
| Product family | SAK Series, Accessories |
|----------------|-------------------------|

Classifications

| | | | |
|------------|-------------|------------|-------------|
| ETIM 3.0 | EC000489 | UNSPSC | 30-21-18-01 |
| eClass 5.1 | 27-14-11-40 | eClass 6.2 | 27-14-11-40 |
| eClass 7.1 | 27-14-11-40 | | |

Product information

| | |
|---------------------------------|---|
| Descriptive text technical data | The mounting tolerances of the terminals must be taken into account. When used with a cross-connector, the rated cross-section should be reduced to the next smallest diameter. |
|---------------------------------|---|

Approvals

| | |
|-----------|---|
| Approvals |  |
| ROHS | Conform |